



# CITY OF SUMTER

## 2018 ANNUAL WATER QUALITY REPORT

### System No. 4310001



The City of Sumter is pleased to present this year's Annual Water Quality Report (Consumer Confidence Report). This report is designed to provide details and to assure you that the water is both safe and dependable. Your water source is ground water from deep wells. These wells draw water from the Black Creek & Middendorf Aquifers. The water is then treated in a "treatment train" that can include coagulation, flocculation, sedimentation, filtration and disinfection.

The City is pleased to report that your drinking water is safe and meets all Federal and State requirements. Sumter City Council serves as the Water Utility Board with their meetings held the first and third Tuesday's of each month at 5:30 p.m. in The Opera House at 21 North Main Street. You are welcome to attend any of their meetings.

As water travels over the land or underground, it can pick up substance or constituents such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some amount of some constituent. It's important to remember that the presence of constituents does not necessarily pose a health risk. More information about constituents and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

The City of Sumter routinely monitors your drinking water, as required by SC DHEC and EPA, for microbiological, radioactive, inorganic, synthetic organic, and volatile organic constituents. We have always met these requirements and want you to know that we pay special attention to all rules. In the monitoring period of January 1, 2013 to December 31, 2018 all required tests were conducted for individual constituents in your drinking water. Twelve constituents were detected; all at levels well below the safe drinking water level. The attached "Analysis Result" table gives information on our testing and verifies that no constituent exists that could cause any potential health concern.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Sumter is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.** When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Unregulated Contaminant Monitoring Rule (UCMR) contaminants are used to evaluate and prioritize contaminants on the Drinking Water Contaminant Candidate List, a list of contaminants EPA is considering for possible new drinking water standards. Data collected through the monitoring of these contaminants will help to ensure that future decisions on drinking water standards are based on sound science. Not all systems are required to monitor for these contaminants.

As you can see by the table, our system had no violations; The City of Sumter is proud that your drinking water meets or exceeds all Federal and State requirements. If you have questions about this report or need to report a problem concerning water utilities please call City Public Services at 803-436-2558. We ask that you continue to help us protect this valuable resource and report any concerns to our offices.

Sincerely,  
Joseph T. McElveen, Jr. Mayor



# CITY OF SUMTER

## 2018 ANNUAL WATER QUALITY REPORT

### System No. 4310001



CONSTITUENT (UNIT OF MEASURE)	MCLG	MCL	HIGHEST DETECTED LEVEL	VIOLATION? YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>INORGANIC CHEMICALS</b>						
Barium (ppm)	2	2	0.099	No	2017	Erosion of natural deposits.
Beryllium (ppm)	4	4	0.001	No	2017	Discharge from metal refineries and coal
Fluoride (ppm)	4	4	0.77	No	2017	Erosion of natural deposits; water additive which promotes strong teeth.
Combined Radium 226/228 (pCi/L)	0	5	1.55	No	2013	Erosion of natural deposits.
<b>DISINFECTANTS / DISINFECTION BY PRODUCTS</b>						
	MRDL	MRDLG				TYPICAL SOURCE OF CONSTITUENT
Chlorine(ppm)	4	4	0.77	No	2018	Water additive used to control microbes
TTHM (ppb)	N/A	80	3.9	No	2018	By-product of drinking water chlorination.
Haloacetic Acids (ppb)	N/A	60	2.4	No	2018	By-product of drinking water chlorination.
<b>LEAD &amp; COPPER</b>						
	ACTION LEVEL	90TH PERCENTILE	NUMBER OF SITES OVER ACTION LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
Copper (ppm)	1.3	0.026	0	No	2018	Corrosion of household plumbing systems
Lead (ppb)	15	0.9	0	No	2018	Corrosion of household plumbing systems
<b>UNREGULATED CONTAMINANT MONITORING</b>						
	ACTION LEVEL		HIGHEST DETECTED LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
HAA5(ppb)	N/A		1.22	No	2018	By-product of drinking water chlorination
HAA6(ppb)	N/A		0.42	No	2018	By-product of drinking water chlorination
HAA9(ppb)	N/A		0.758	No	2018	By-product of drinking water chlorination

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** - one part per million corresponds to a single penny in \$10,000.

**Parts per billion (ppb)** - one part per billion corresponds to a single penny in \$10,000,000.

**Picocuries per liter (pCi/l)** - picocuries per liter is a measure of the radioactivity in water

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risks to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



# DALZELL WATER DISTRICT

## 2018 ANNUAL WATER QUALITY REPORT

### System No. 4320001



The City of Sumter is pleased to provide you with this year's Annual Water Quality Report, a requirement of Consumer Confidence Reporting. The report is required by DHEC and EPA to inform you about the water provided by the City of Sumter and to assure you that the water is both safe and dependable. Your water source is ground water from wells. These wells draw water from the Upper Black Creek Aquifer. DHEC has completed an assessment of our source water. The Source Water Assessment (SWAP) is no longer available on the DHEC web site. It can be requested through FOI so therefore the link has changed to the following <http://www.scdhec.gov/HomeAndEnvironment/Water/SourceWaterProtection>

The City is pleased to report that your drinking water is safe and meets all Federal and State requirements. Sumter City Council serves as the Water Utility Board with their meetings held the first and third Tuesday's of each month at 5:30 p.m. in The Opera House at 21 North Main Street. You are welcome to attend any of their meetings.

As water travels over the land or underground, it can pick up substance or constituents such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some amount of some constituent. It's important to remember that the presence of constituents does not necessarily pose a health risk. More information about constituents and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

The City of Sumter routinely monitors your drinking water, as required by SC DHEC and EPA, for microbiological, radioactive, inorganic, synthetic organic, and volatile organic constituents. We have always met all of these requirements and want you to know that we pay special attention to all rules. In the monitoring period of January 1, 2014 to December 31, 2018 all required tests were conducted for individual constituents in your drinking water. Five constituents were detected; all at levels well below the safe drinking water level. The attached "Analysis Result" table gives information on our testing and verifies that no constituent exists that could cause any potential health concern.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Sumter is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.** When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

As you can see by the table, our system had no violations; The City of Sumter is proud that your drinking water meets or exceeds all Federal and State requirements. If you have questions about this report please call City Public Services at 803-436-2558 during normal business hours. If you need to report a problem concerning water utilities you can call City Public Services at 803-436-2558 24 hours per day. We ask that you continue to help us protect this valuable resource and report any concerns to our offices.

Sincerely,  
Joseph T. McElveen, Jr. Mayor



# DALZELL WATER DISTRICT

## 2018 ANNUAL WATER QUALITY REPORT

### System No. 4320001



CONSTITUENT (UNIT OF MEASURE)	MCLG	MCL	HIGHEST DETECTED LEVEL	VIOLATION? YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>INORGANIC CHEMICALS</b>						
Nitrate (ppm)	10	10	2.3	No	2018	Runoff from fertilizer use.
Gross Alpha Exc. Radon & Uranium (pCi/L)	0	15	3.09	No	2014	Erosion of Natural Deposits
<b>DISINFECTANTS &amp; DISINFECTANT BYPRODUCTS</b>						
	MRDL	MRDLG				
Chlorine(ppm)	4	4	1.4	No	2018	Water additive used to control microbes
<b>LEAD &amp; COPPER</b>						
	ACTION LEVEL	90TH PERCENTILE	NUMBER OF SITES OVER ACTION LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
Copper (ppm)	1.3	0.0054	0	No	2016	Corrosion of household plumbing systems
Lead (ppb)	15	0	0	No	2016	Corrosion of household plumbing systems

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** - one part per million corresponds to a single penny in \$10,000.

**Parts per billion (ppb)** - one part per billion corresponds to a single penny in \$10,000,000.

**Picocuries per liter (pCi/l)** - picocuries per liter is a measure of the radioactivity in water

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risks to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



# OSWEGO RURAL WATER 2018 ANNUAL WATER QUALITY REPORT System No. 4320006



The City of Sumter is pleased to provide you with this year's Annual Water Quality Report, a requirement of Consumer Confidence Reporting. The report is required by DHEC and EPA to inform you about the water provided by the City of Sumter and to assure you that the water is both safe and dependable. Your water source is ground water from deep wells. These wells draw water from the Black Creek & Middendorf Aquifers. DHEC has completed an assessment of our source water. The Source Water Assessment (SWAP) is no longer available on the DHEC web site. It can be requested through FOI so therefore the link has changed to the following <http://www.scdhec.gov/HomeAndEnvironment/Water/SourceWaterProtection>.

The City is pleased to report that your drinking water is safe and meets all Federal and State requirements. Sumter City Council serves as the Water Utility Board with their meetings held the first and third Tuesday's of each month at 5:30 p.m. in The Opera House at 21 North Main Street. You are welcome to attend any of their meetings.

As water travels over the land or underground, it can pick up substance or constituents such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some amount of some constituent. It's important to remember that the presence of constituents does not necessarily pose a health risk. More information about constituents and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

The City of Sumter routinely monitors your drinking water, as required by SC DHEC and EPA, for microbiological, radioactive, inorganic, synthetic organic, and volatile organic constituents. We have always met all of these requirements and want you to know that we pay special attention to all rules. In the monitoring period of January 1, 2013 to December 31, 2018 all required tests were conducted for individual constituents in your drinking water. Eight constituents were detected; all at levels well below the safe drinking water level. The attached "Analysis Result" table gives information on our testing and verifies that no constituent exists that could cause any potential health concern.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.** The City of Sumter is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

As you can see by the table, our system had no violations; The City of Sumter is proud that your drinking water meets or exceeds all Federal and State requirements. If you have questions about this report please call City Public Services at 803-436-2558 during normal business hours. If you need to report a problem concerning water utilities you can call City Public Services at 803-436-2558 24 hours per day. We ask that you continue to help us protect this valuable resource and report any concerns to our offices.

Sincerely,  
Joseph T. McElveen, Jr. Mayor



# OSWEGO RURAL WATER 2018 ANNUAL WATER QUALITY REPORT System No. 4320006



CONSTITUENT (UNIT OF MEASURE)	MCLG	MCL	HIGHEST DETECTED LEVEL	VIOLATION? YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>INORGANIC CHEMICALS</b>						
Barium (ppm)	2	2	0.099	No	2017	Erosion of natural deposits.
Beryllium	4	4	0.001	No	2017	Discharge from metal refineries & coal.
Fluoride (ppm)	4	4	0.77	No	2017	Erosion of natural deposits; water additive which promotes strong teeth.
Combined Radium 226/228 (pCi/L)	0	5	1.55	No	2013	Erosion of Natural Deposits
<b>DISINFECTANTS &amp; DISINFECTANT BYPRODUCTS</b>						
Chlorine(ppm)	4	4	0.61	No	2018	Water additive used to control microbes
Halocetic Acids (HAA5) (ppb)	N/A	60	2.8	No	2017	By-product of drinking water chlorination.
Total Trihalomethanes (ppb)	N/A	80	3.9	No	2017	By-product of drinking water chlorination.
<b>LEAD &amp; COPPER</b>						
	ACTION LEVEL	90TH PERCENTILE	NUMBER OF SITES OVER ACTION LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
Copper (ppm)	1.3	0.018	0	No	2018	Corrosion of household plumbing systems
Lead (ppb)	15	0.2	0	No	2018	Corrosion of household plumbing systems

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** - one part per million corresponds to a single penny in \$10,000.

**Parts per billion (ppb)** - one part per billion corresponds to a single penny in \$10,000,000.

**Picocuries per liter (pCi/l)** - picocuries per liter is a measure of the radioactivity in water

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risks to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



# TOWN OF MAYESVILLE WATER SYSTEMS 2018 ANNUAL WATER QUALITY REPORT System No. 4310003



The City of Sumter is pleased to provide you with this year's Annual Water Quality Report, a requirement of Consumer Confidence Reporting. The report is required by SC DHEC and EPA to inform you about the water provided by the City of Sumter and to assure you that the water is both safe and dependable. Your water source is ground water from wells. These wells draw water from the Upper Black Creek Aquifer. DHEC has completed an assessment of our source water. The Source Water Assessment (SWAP) is no longer available on the DHEC web site. It can be requested through FOI so therefore the link has changed to the following <http://www.scdhec.gov/HomeAndEnvironment/Water/SourceWaterProtection>.

The City is pleased to report that your drinking water is safe and meets all Federal and State requirements. Sumter City Council serves as the Water Utility Board with their meetings held the first and third Tuesday's of each month at 5:30 p.m. in The Opera House at 21 North Main Street. You are welcome to attend any of their meetings.

As water travels over the land or underground, it can pick up substance or constituents such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some amount of some constituent. It's important to remember that the presence of constituents does not necessarily pose a health risk. More information about constituents and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

The City of Sumter routinely monitors your drinking water, as required by SC DHEC and EPA, for microbiological, radioactive, inorganic, synthetic organic, and volatile organic constituents. We have always met all of these requirements and want you to know that we pay special attention to all rules. In the monitoring period of January 1, 2015 to December 31, 2018 all required tests were conducted for individual constituents in your drinking water. Four constituents were detected; all within a range below the safe drinking water level.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.** The City of Sumter is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The City of Sumter works continuously to provide you with a safe and reliable source of drinking water. If you have questions about this report please call 803-436-2558 during regular business hours. If you need to report a problem concerning water utilities you can call City Public Services at 803-436-2558 24 hours per day. We ask that you continue to help us protect this valuable resource and report any concerns to our offices.

Sincerely,  
Joseph T. McElveen, Jr.  
Mayor



# TOWN OF MAYESVILLE WATER SYSTEM 2018 ANNUAL WATER QUALITY REPORT

## System No. 4310003



CONSTITUENT (UNIT OF MEASURE)	MCLG	MCL	HIGHEST DETECTED LEVEL	VIOLATION? YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>INORGANIC CHEMICALS</b>						
Combined radium (pCi/l)	0	5	Range of Detects 0.0 – 1.5	No	2018	Erosion of Natural Deposits.
Gross Alpha Excl. Rad & Uran (pCi/l)	0	15	Range of Detects 0.0 – 2.0	No	2018	Erosion of Natural Deposits.
<b>DISINFECTANTS</b>						
	MRDL	MRDLG				
Chlorine (ppm)	4	4	1.1	No	2018	Water additive used to control microbes.
<b>LEAD &amp; COPPER</b>						
	ACTION LEVEL	90TH PERCENTILE	NUMBER OF SITES OVER ACTION LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
Copper (ppm)	1.3	0.0061	0	No	2016	Corrosion of household plumbing systems.
Lead (ppb)	15	0	0	No	2016	Corrosion of household plumbing systems.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** - one part per million corresponds to a single penny in \$10,000.

**Picocuries per liter (pCi/l)** - picocuries per liter is a measure of the radioactivity in water

**Parts per billion (ppb)** - one part per billion corresponds to a single penny in \$10,000,000.

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risks to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.



# WESSEX SUBDIVISION WATER SYSTEMS 2018 ANNUAL WATER QUALITY REPORT System No. 4350016



The City of Sumter is pleased to provide you with this year's Annual Water Quality Report, a requirement of Consumer Confidence Reporting. The report is required by SC DHEC and EPA to inform you about the water provided by the City of Sumter and to assure you that the water is both safe and dependable. Your water source is ground water from wells. These wells draw water from the Upper Black Creek Aquifer. DHEC has completed an assessment of our source water. The Source Water Assessment (SWAP) is no longer available on the DHEC web site. It can be requested through FOI so therefore the link has changed to the following <http://www.scdhec.gov/HomeAndEnvironment/Water/SourceWaterProtection> .

The City is pleased to report that your drinking water is safe and meets all Federal and State requirements. Sumter City Council serves as the Water Utility Board with their meetings held the first and third Tuesday's of each month at 5:30 p.m. in The Opera House at 21 North Main Street. You are welcome to attend any of their meetings.

As water travels over the land or underground, it can pick up substances or constituents such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some amount of some constituent. It's important to remember that the presence of constituents does not necessarily pose a health risk. More information about constituents and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

The City of Sumter routinely monitors your drinking water, as required by The State and EPA, for microbiological, radioactive, inorganic, synthetic organic, and volatile organic constituents. We have always met all of these requirements and want you to know that we pay special attention to all rules. In the monitoring period of January 1, 2013 to December 31, 2018 all required tests were conducted for individual constituents in your drinking water. Six constituents were detected; all at levels well below the safe drinking water level. The attached "Analysis Result" table gives information on our testing and verifies that no constituent exists that could cause any potential health concern.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.** The City of Sumter is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek the advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

As you can see by the table, our system had no violations; The City of Sumter is proud that your drinking water meets or exceeds all Federal and State requirements . If you have questions about this report please call 803-436-2558 during regular business hours. If you need to report a problem concerning water utilities you can call City Public Services at 803-436-2558 24 hours per day. We ask that you continue to help us protect this valuable resource and report any concerns to our offices.

Sincerely,  
Joseph T. McElveen, Jr. Mayor



# WESSEX SUBDIVISON WATER SYSTEM 2018 ANNUAL WATER QUALITY REPORT System No. 4350016



CONSTITUENT (UNIT OF MEASURE)	MCLG	MCL	HIGHEST DETECTED LEVEL	VIOLATION? YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>INORGANIC CHEMICALS</b>						
Nitrate (ppm)	10	10	3.6	No	2018	Runoff from fertilizer use.
Combined Radium 226/228 (pCi/L)	0	5	1.55	No	2013	Erosion of Natural Deposits
<b>ORGANIC CHEMICALS</b>						
Dibromochloropropane (ppb)	0	0.02	0.032	No	2018	Runoff/leaching from soil fumigant used on soybeans and cotton.
Dichloropropane (ppb)	0	5	0.81	No	2018	Discharge from industrial chemical factories.
<b>DISINFECTANTS</b>						
	MRDL	MRDLG				
Chlorine(ppm)	4	4	1.5	No	2018	Water additive used to control microbes
	ACTION LEVEL	90TH PERCENTILE	NUMBER OF SITES OVER ACTION LEVEL	VIOLATION YES/NO	YEAR SAMPLED	TYPICAL SOURCE OF CONSTITUENT
<b>LEAD &amp; COPPER</b>						
Copper (ppm)	1.3	0.09	0	No	2018	Corrosion of household plumbing systems
Lead (ppb)	15	3.4	0	No	2018	Corrosion of household plumbing systems

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** - one part per million corresponds to a single penny in \$10,000.

**Parts per trillion (ppb)** - one part per trillion corresponds to a single penny in \$10,000,000,000

**Picocuries per liter (pCi/l)** - picocuries per liter is a measure of the radioactivity in water

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risks to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.